

STRUCTURAL ENGINEERING DIVISION

Test Floor Laboratory Department of Civil Engineering University of Engineering and Technology Lahore, 54890 Pakistan. Ph: 92-42-99029202

To, M/S H. Developments Construction Garden Town, Lahore

Reference # CED/TFL **35175** (Dr. Waseem Abbas)

Reference of the request letter # Nil

Dated: 27-07-2020

Dated: 27-07-2020

Tension Test Report (Page -1/1)

Date of Test 28-07-2020 Gauge length 8 inches

Description Deformed Steel Bar Tensile and Bend Test as per ASTM-A615

Nominal Actual	inal					Yield Stress (psi)		Ultimate Stress (psi)		Elongation	Remarks
ž *	Nominal	Actual	(kg)	(kg)	Nominal	Actual	Nominal	Actual	(inch)	% E	R
3/8 0.37	0.11	0.108	3000	4600	60200	61050	92200	93600	1.30	16.3	
	-	-	•	-	-	-	-	•	-	•	
	-	-	-	-	-	-	-	-	-		
	-	-	-	-	-	-	-	-	-		
	-	-	-	-	-	-	-	-	-	-	
	-	-	-	-	-	-	-	-	-	-	
Note: only one sample for tensile and one sample for bend test											
				DandT	\\						
3	6/8 0.371 	/8 0.371 0.11	7/8 0.371 0.11 0.108	1/8 0.371 0.11 0.108 3000 - - - - - - - - - - - - - - - - - - - - - - - - - - - - - -		6/8 0.371 0.11 0.108 3000 4600 60200 - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - -					

3/8" Dia Bar Bend Test Through 180° is Satisfactory

I/C Testing Laboratoires UET Lahore, Pakistan.

Note:

- 1- You can See your reports On Internet in the following web site http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports
- 2. The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples



STRUCTURAL ENGINEERING DIVISION

Test Floor Laboratory Department of Civil Engineering University of Engineering and Technology Lahore, 54890 Pakistan. Ph: 92-42-99029202

To,
Resident Engineer
Osmani & Company (Pvt) Ltd
M-3 IC Industrial City, Faisalabad

Reference # CED/TFL **35176** (Dr. Waseem Abbas)

Reference of the request letter # CRE/M4IC/AIIC/Lab/527

Dated: 27-07-2020

Dated: 27-07-2020

Tension Test Report (Page -1/1)

Date of Test 28-07-2020 Gauge length 8 inches

Description Deformed Steel Bar Tensile and Bend Test as per ASTM-A615

Sr. No.	Weight	Diameter/ Size		Area (in²)		Yield load	Breaking Load	Yield Stress (psi)		Ultimate Stress (psi)		Elongation	% Elongation	Remarks
	(lbs/ft)	Nominal (#)	Actual (inch)	Nominal	Actual	(kg)	(kg)	Nominal	Actual	Nominal	Actual	(inch)	% E	Ŗ
1	0.385	3	0.379	0.11	0.113	3300	5000	66200	64330	100200	97500	1.20	15.0	d
2	0.378	3	0.376	0.11	0.111	3000	4900	60200	59500	98200	97200	1.20	15.0	Ittehad Steel
-	-	-	-	-	-	-	-	-	-	-	-	-	-	I
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Note: only two samples for tensile and one sample for bend test														
Bend Test														
#3 Bar Bend Test Through 180° is Satisfactory														

I/C Testing Laboratoires UET Lahore, Pakistan.

Note:

- 1- You can See your reports On Internet in the following web site http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports
- 2. The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples