



**STRUCTURAL ENGINEERING DIVISION**  
**Test Floor Laboratory**  
**Department of Civil Engineering**  
**University of Engineering and Technology Lahore, 54890**  
**Pakistan. Ph: 92-42-99029202**

To,  
Resident Engineer  
Al-Imam Enterprises (Pvt) Ltd.  
Construction of Penta Square, Phase-V, D.H.A, Lahore

Reference # CED/TFL **34889** (Dr. Safer Abbas)  
Reference of the request letter # Al-Imam/746/PS-1/DHA/LHE/1083

Dated: 11-05-2020  
Dated: 07-05-2020

**Tension Test Report** (Page – 1/2)

Date of Test 18-05-2020  
Gauge length 640 mm  
Description Steel Strand Tensile Test as per ASTM A-416-94a

Sr. No.	Nominal Diameter	Nominal Weight	Measured weight	Yield strength clause (6.3)		Breaking strength clause (6.2)		Young's Modulus of Elasticity "E"	% Elongation	Remarks / Coil No.
	(mm)	(kg/km)	(kg/km)	(kg)	(kN)	(kg)	(kN)	GPa		
1	12.70 (1/2")	775.0	787.0	17400	170.69	19600	192.28	199	>3.50	xx
-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	
<b>Only one sample for Test</b>										

Note:

1. Modulus of Elasticity is based on nominal steel area of the steel strand vide clause 13.3 of ASTM – A416a
2. Load versus percentage strain graphs are attached

**I/C Testing Laboratoires**  
**UET Lahore, Pakistan.**

Note:

- 1- You can See your reports On Internet in the following web site  
[http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing\\_reports](http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports)
2. The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples



**STRUCTURAL ENGINEERING DIVISION**  
**Test Floor Laboratory**  
**Department of Civil Engineering**  
**University of Engineering and Technology Lahore, 54890**  
**Pakistan. Ph: 92-42-99029202**

To,  
Resident Engineer  
Al-Imam Enterprises (Pvt) Ltd.  
Construction of Penta Square, Phase-V, D.H.A, Lahore


Reference # CED/TFL **34889** (Dr. Safer Abbas)

Dated: 11-05-2020

Reference of the request letter # Al-Imam/746/PS-1/DHA/LHE/1083

Dated: 07-05-2020

**Graph** (Page – 2/2)



**I/C Testing Laboratories**  
**UET Lahore, Pakistan.**

**Note:**

- 1- You can See your reports On Internet in the following web site  
[http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing\\_reports](http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports)
- 2- The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples