



**STRUCTURAL ENGINEERING DIVISION**  
**Test Floor Laboratory**  
**Department of Civil Engineering**  
**University of Engineering and Technology Lahore, 54890**  
**Pakistan. Ph: 92-42-99029202**

To,  
Resident Engineer-III  
CEC-Minconsult (Jv)  
Khyber Pakhtunkhwa Provincial Road Improvement Project (KP-PRIP)  
Khair abd – Kahi-Nizampur Road Section (S-6) (23.11 km)

Reference # CED/TFL **34910** (Dr. Safer Abbas)

Dated: 18-05-2020

Reference of the request letter # JV Min – CEC/PRIP/RE-III/2020/112

Dated: 14-05-2020

**Tension Test Report** (Page – 1/2)

Date of Test 21-05-2020

Gauge length 640 mm

Description Steel Strand Tensile Test as per ASTM A-416-94a

Sr. No.	Nominal Diameter	Nominal Weight	Measured weight	Yield strength clause (6.3)		Breaking strength clause (6.2)		Young's Modulus of Elasticity "E"	% Elongation	Remarks / Coil No.
	(mm)	(kg/km)	(kg/km)	(kg)	(kN)	(kg)	(kN)	GPa		
1	12.70 (1/2")	775.0	784.0	18000	176.58	19800	194.24	199	>3.50	xx
-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	
<b>Only one sample for Test</b>										

Note:

1. Modulus of Elasticity is based on nominal steel area of the steel strand vide clause 13.3 of ASTM – A416a
2. Load versus percentage strain graphs are attached

**I/C Testing Laboratoires**  
**UET Lahore, Pakistan.**

Note:

- 1- You can See your reports On Internet in the following web site  
[http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing\\_reports](http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports)
2. The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples



**STRUCTURAL ENGINEERING DIVISION**  
**Test Floor Laboratory**  
**Department of Civil Engineering**  
**University of Engineering and Technology Lahore, 54890**  
**Pakistan. Ph: 92-42-99029202**

To,  
Resident Engineer-III  
CEC-Minconsult (Jv)  
Khyber Pakhtunkhwa Provincial Road Improvement Project (KP-PRIP)  
Khair abd – Kahi-Nizampur Road Section (S-6) (23.11 km)


Reference # CED/TFL **34910** (Dr. Safer Abbas)

Dated: 18-05-2020

Reference of the request letter # JV Min – CEC/PRIP/RE-III/2020/112

Dated: 14-05-2020

**Graph** (Page – 2/2)



**I/C Testing Laboratories**  
**UET Lahore, Pakistan.**

**Note:**

- 1- You can See your reports On Internet in the following web site  
[http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing\\_reports](http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports)
- 2- The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples